

คำนำ

“พ็อกเก็ตบุค ENGINEERING REFERENCE ฉบับคู่มือ วิศวกรรมฉบับนี้ บริษัท มีราเดิล อินเตอร์เนชันแนล เทคโนโลยี จำกัด หรือ MIT ได้รวบรวมขึ้นจากหลายแหล่ง อาทิ เว็บไซต์ และ ประสบการณ์ต่างๆ ข้อมูลความรู้ที่เป็นลิ่งจัมเป็นทางด้านวิศวกรรม ทุกประเภท จัดทำเป็นคู่มือที่สามารถหาค่าตารางแปลงหน่วย ที่รวดเร็ว และแม่นยำ ทำให้วิศวกรทุกท่านได้บริหารเวลาได้อย่าง มีประสิทธิภาพมากขึ้น และเพื่อเผยแพร่เป็นสาธารณประโยชน์ ไม่ใช่เอกสารทางวิชาการที่แสวงหาประโยชน์ทางการค้าหรือ ประโยชน์ใดๆ หวังว่าคู่มือฉบับนี้จะให้ประโยชน์แก่ทุกท่าน ไม่มาก ก็น้อย”

บริษัท มีราเดิล อินเตอร์เนชันแนล เทคโนโลยี จำกัด

สารบัญ

- 6 - 9 คัพท์สอบเที่ยบน้ำร้อน จาก MIT
- 10 - 12 การแปลงหน่วยทั่วไป
- 13 ตารางแปลงอุณหภูมิ
- 14 ตารางเทียบหน่วยน้ำหนัก เมตริก, อังกฤษ, สหรัฐ
- 15 ตารางเทียบหน่วยปริมาตร เมตริก, อังกฤษ, สหรัฐ
- 16 ตารางแปลงหน่วยของโอลต์
- 17 General Metric Conversion Factors
 - Conversion Table for Pressure
 - Glossry of Pressure Units
- 18 Torque Conversion Factors
- 19 Steam Table
- 20 Basic Properties of Plastics
 - U.S. Mesh to Micron Particle Size Conversion
- 21 Viscosity Conversion Chart
- 22 Chemical Resistance of Material
- 23 Reference Range of Temperature
- 24 NEMA Ratings, Enclosure Classifications and Type
- 25 ค่าการนำกระแสสูงสุดของสายไฟฟ้า
- 26 จำนวนสายสูงสุดภายในท่อร้อยสายไฟฟ้า
- 27 ขนาด สาย, ท่อ, เชอร์กิตเบรคเกอร์ ตามขนาดมาตรฐานท่อร์ที่ 1

สารบัญ

- 28 ขนาด สาย, ท่อ, เชอร์กิตเบรคเกอร์ ตามขนาดมอเตอร์ที่ 2
29 ขนาด สาย, ท่อ, เชอร์กิตเบรคเกอร์ ตามขนาดมอเตอร์ที่ 3
30 ขนาด สาย, ท่อ, เชอร์กิตเบรคเกอร์ ตามขนาดมิเตอร์ไฟฟ้า
สายดินตามขนาดเชอร์กิตเบรคเกอร์
31 คุณสมบัติของหลอดไฟฟ้า
32 - 34 ค่าความเข้มของแสงสำหรับงานลักษณะต่างๆ
35 - 36 การคำนวณ Heat transfer และสูตร Heat load
37 ตารางคำนวณค่า U
38 - 44 ตารางวัสดุสำหรับส่วนต่างๆ ของอาคาร
45 ขอบข่ายการให้บริการสอบเทียบ

ศัพท์สอนเที่ยบนำร่อง จาก MIT

หน่วยเอสไอ (SI) มีชื่อเต็มว่า International System of Units หรือ Systeme International d'Units หรือ SI UNITS

เป็นระบบหน่วยระหว่างชาติ ประกอบด้วย 2 ส่วน คือ

1. หน่วยฐาน (Base Units) เป็นหน่วยหลักของระบบเอสไอ ประกอบด้วยทั้งหมด 7 หน่วย ได้แก่ เมตร (m) กิโลกรัม (kg) วินาที (s) แอมป์เรีย (A) เคลวิน (K) โมล (mol) แคนเดลา (cd)
2. หน่วยอนุพันธ์ (Derived Units) เป็นหน่วยฐานหลาย ๆ หน่วย มาเกี่ยวข้องกัน เช่น เฮิรตซ์ (Hz) นิวตัน (N) จูล (J) วัตต์ (W) คูลومบ์ (C) โวลต์ (V) พาสคัล (Pa) เชลเซียส ($^{\circ}\text{C}$)

คำศัพท์มาตรฐานวิทยา

Accuracy of measurement (ความแม่นยำของการวัด) คือ ค่าความถูกต้องใกล้เคียงกัน ระหว่างผลของการวัดกับค่าจริง
Adjustment (การปรับ) คือการปรับแต่งให้เครื่องมือวัดอยู่ในสมรรถนะที่กำหนด

Calibration (การสอบเที่ยบ) คือปฏิบัติการเพื่อการตรวจสอบคุณสมบัติทางมาตรฐานวิทยาของเครื่อง ด้วยการวัดเทียบค่าที่เครื่องอ่านได้กับค่าของตัวมาตรฐาน

Correction factor (ตัวประกอบการปรับแก้) คือตัวเลขใช้คูณกับค่า ยังไม่ปรับแก้ของการวัด เพื่อชดเชยค่าความผิดพลาด

Correction (ค่าปรับแก้) คือค่าที่ชดเชยสำหรับค่าผิดพลาดโดยนำมา บวกกับค่า yang ไม่ปรับแก้ของการวัด

Corrected result (ค่าปรับแก้) ผลของการวัดที่ได้หลังการปรับแก้ค่า

Instrumental drift การเปลี่ยนแปลงที่ต่อเนื่องหรือการเปลี่ยนแปลง ที่เพิ่มขึ้นตามเวลาในค่าบ่งชี้เนื่องจากการเปลี่ยนแปลงในสมบัติเชิง มาตรวิทยาของเครื่องมือวัดเครื่องหนึ่ง

Maximum permissible errors; MPE (ความคลาดเคลื่อนสูงสุด ที่ยอมรับได้) คือความคลาดเคลื่อนของเครื่องมือวัดที่ยอมให้ เกิดขึ้นได้มากที่สุดตามวัตถุประสงค์ของการใช้งาน บางครั้งอาจ เรียกว่า tolerance

Hysteresis คือผลต่างสูงสุดของค่าที่อ่านได้จากอุปกรณ์วัดจากค่าที่ แท้จริงระหว่างการอ่านข้ามกับการอ่านขالงที่จุดๆ เดียวกัน

International standard (มาตรฐานระหว่างประเทศ) มาตรฐานซึ่ง รับรองโดยข้อตกลงระหว่างประเทศสำหรับใช้เป็นมูลฐานระหว่าง ประเทศ ในการกำหนดค่ามาตรฐานอื่นๆ

Intermediate check (การตรวจสอบเครื่องมือระหว่างการใช้งาน) คือการตรวจสอบเครื่องมือเป็นระยะ ระหว่างช่วงการสอบเทียบ อาจจะกำหนดให้ทำทุกหนึ่งเดือนหรือนานกว่า

Primary Standard (มาตรฐานปฐมภูมิ) มาตรฐานซึ่งมีคุณภาพ
ทางมาตรวิทยาสูงสุด

Result of a measurement (ผลของการวัด) คือค่าของปริมาณที่วัด
ได้จากการวัด

Repeatability of measurements (การวนซ้ำได้ของการวัด)
คือ ความถูกต้องใกล้เคียงกันระหว่างผลการวัดซ้ำ ที่เดียวกัน
หลาย ๆ ครั้ง

Reference standard (มาตรฐานอ้างอิง) มาตรฐานที่มีคุณภาพสูงสุด
ทางมาตรวิทยามืออยู่ ณ สถานที่กำหนดให้ ที่การวัดต่าง ๆ

Reference condition (ภาวะอ้างอิง) ภาวะการใช้ของเครื่องมือวัด
ที่กำหนดสำหรับการทดสอบสมรรถนะ

Response characteristic (ลักษณะการตอบสนอง) คือความ
สัมพันธ์ระหว่างสิ่งเร้ากับผลตอบสนอง

Resolution (ความละเอียด) คือค่าที่เล็กสุดที่เครื่องสามารถแสดงผล
ได้ในช่วงการวัดนั้นๆ

Secondary standard (มาตรฐานทุติยภูมิ) มาตรฐานซึ่งถูกกำหนด
ค่าโดยการเปรียบเทียบกับมาตรฐานปฐมภูมิ

Span (ช่วงการวัด) ขนาดของความแตกต่าง ระหว่างขีดจำกัดของ
พิลัยระบุเครื่องวัด

Sensitivity (ความไว) การเปลี่ยนแปลงของผลตอบสนองของเครื่องวัด หารด้วยการเปลี่ยนแปลงของสิ่งเร้า

Traceability (ความสอบกลับได้) คุณสมบัติของผลการวัดที่สามารถสอบกลับมาตรวจสอบที่เหมาะสม โดยการเปรียบเทียบอย่างต่อเนื่อง กันเป็นลูกโซ่ถึงมาตรฐานระหว่างประเทศ

Uncertainty of measurement (ความไม่แน่นอนของการวัด)
คือการประมาณบอกลักษณะในพิสัยของค่า ซึ่งครอบคลุมค่าจริงของปริมาณที่วัด

Working standard (มาตรฐานใช้งาน) มาตรฐานที่ได้สอบเทียบกับมาตรฐานอ้างอิงใช้ประจำในการสอบเทียบ

Precision (ความเที่ยงตรง) คือ ความสามารถในการวัดให้ได้ค่าใกล้เคียงกับค่าเดิม

Error (ความคลาดเคลื่อน) คือ ความแตกต่างของค่าที่วัดได้กับค่าจริง

Verification (การทวนสอบ) คือ การทดสอบเพื่อหาการเลื่อนค่าของเครื่องมือวัดก่อน-หลังจากสอบเทียบ

การแปลงหน่วย

quantity	symbol	unit	U.S. relationship
acceleration	m/s^2	metres per second squared	$1m/s^2 = 3.281 \text{ ft/sec}^2$
angular velocity	rad/s	radians per second	$1 \text{ rad/sec} = 9.549 \text{ rpm}$
area	m^2	square metre	$1 m^2 = 10.76 \text{ sq ft}$
atmospheric pressure	-	101.325 kPa	29.92 in Hg = 14.696 psi
density	kg/m^3	kilograms per cubic metre	$1kg/m^3 = 0.0624 \text{ lb/cu ft}$
density air	-	1.2 kg/m^3	0.075 lb/cu ft
density water	-	1000 kg/m^3	62.4 lb/cu ft
duct friction loss	Pa/m	pascals per metre	$1 \text{ Pa/m} = 0.1224 \text{ in.w.g./100}$
enthalpy	kJ/kg	kilogram	$1 \text{ kJ/kg} = 0.4299 \text{ Btu/lb dry air}$
gravity		9.8067 m/s^2	32.2 ft/sec^2
heat flow	W	watt	$1 \text{ W} = 3.412 \text{ Btu/hr}$
length (normal)	m	metre	$1 \text{ m} = 3.281 \text{ ft} = 39.37 \text{ in.}$
linear velocity	m/s	metres per second	$1 \text{ m/s} = 196.9 \text{ fpm}$
mass flow rate	kg/s	kilograms per second	$1 \text{ kg/s} = 7936.6 \text{ lb/hr}$
moment of inertia	$kg.m^2$	kilograms x square metre	$1 \text{ kg.m}^2 = 23.73 \text{ lb.sq ft}$
power	W	watt	$1 \text{ W} = 0.00134 \text{ hp}$
pressure	kPa Pa	kilopascal (1000 pascals) pascal	$1 \text{ kPa} = 0.296 \text{ in Hg} = 0.145 \text{ psi}$ $1 \text{ Pa} = 0.004015 \text{ in.w.g.}$
specific heat-air (C_p)		$1000 \text{ J/kg.}^\circ\text{C}$	$1000 \text{ J/kg.}^\circ\text{C} = 1 \text{ kJ/kg.}^\circ\text{C}$ $= 0.2388 \text{ Btu/lb } ^\circ\text{F}$
specific heat-air (C_v)		$717 \text{ J/kg.}^\circ\text{C}$	$0.17 \text{ Btu/lb } ^\circ\text{F}$
specific heat-water		$4190 \text{ J/kg.}^\circ\text{C}$	$1.0 \text{ Btu/lb } ^\circ\text{F}$
specific volume	m^3/kg	cubic meters per kilogram	$1 \text{ m}^3/\text{kg} = 16.019 \text{ cu ft/lb}$
thermal conductivity	$W.mm/m^2{}^\circ\text{C}$	watt millimetre per square metre $^\circ\text{C}$	$1W.mm/m^2{}^\circ\text{C}$ $= 0.0069 \text{ Btu.in/ft}^2\text{hr } ^\circ\text{F}$
volume flow rate	m^3/s	cubic metres per second litres per second $1m^3/s = 1000 \text{ l/s}$ $1 \text{ ml} = \text{litres}/1000$	$1m^3/s = 2118.88 \text{ cfm (air)}$ $1 \text{ l/s} = 2.12 \text{ cfm (air)}$ $1m^3/s = 15850 \text{ gpm (water)}$ $1 \text{ ml/s} = 1.05 \text{ gph (water)}$

การแปลงหน่วย

unit	symbol	quantity	equivalent or relationship
ampere	A	electric current	same as U.S.
candela	cd	luminous intensity	$1 \text{ cd}/\text{m}^2 = 0.292 \text{ ft lamberts}$
celsius	°C	temperature	${}^\circ\text{F} = 1.8 {}^\circ\text{C} + 32 {}^\circ$
coulomb	C	electric charge	same as U.S.
farad	F	electric capacitance	same as U.S.
henry	H	electric inductance	same as U.S.
hertz	Hz	frequency	same as cycles per second
joule	J	energy work heat	$1 \text{ J} = 0.7376 \text{ ft-lb}$ $= 0.000948 \text{ Btu}$
kelvin	K	thermodynamic	${}^\circ\text{K} = {}^\circ\text{C} + 273.150$
		Temperature	$= \frac{{}^\circ\text{F} + 459.67}{1.8}$
kilogram	kg	mass	$1 \text{ kg} = 2.2046 \text{ lb}$
litre	l	liquid volume	$1 \text{ l} = 1.056 \text{ qt} = 0.264 \text{ gal}$
lumens	lm	luminous flux	$1 \text{ lm}/\text{m}^2 = 0.0929 \text{ ft candies}$
lux	lx	illuminance	$1 \text{ lx} = 0.0929 \text{ ft candies}$
meter	m	length	$1 \text{ m} = 3.281 \text{ ft}$
mole	mol	amount of substance	-
newton	N	force	$1 \text{ N} = \text{kg.m/s}^2 = 0.2248 \text{ lb (force)}$
ohm		electrical resistance	same as U.S.
pascal	Pa	pressure stress	$1 \text{ Pa} = \text{N/m}^2 = 0.000145 \text{ psi}$ $= 0.004022 \text{ in.w.g.}$
radian	rad	plane angle	$1 \text{ rad} = 57.29 {}^\circ$
second	s	time	same as U.S.
siemens	S	electric conductance	-
steradian	sr	solid angle	-
Volt	V	electric potential	same as U.S.
watt	W	power heat flow	$1 \text{ W} = \text{J/s} = 3.4122 \text{ Btu/hr}$ $1 \text{ W} = 0.000284 \text{ tons of refrigeration}$

$$\mu\text{w/cm}^2 = \text{wm}^2/0.01$$

การแปลงหน่วย

luminance units

	candelas per sq.metre (cd/m ²)	stilb (cd/m ²)	footlambert (fl)
candelas per sq. metre (cd/m ²)	1	10000	3.43
stilb (cd/m ²)	1.10-4	1	3.4.10 ⁻⁴
footlambert (fl)	0,2919	2919	1

illuminance units

units		multiply by	
		→	←
lux (lx)	footcandle (lm/ft ²)	0.0929	10,764

temperature units

units		convert by	
		→	←
°C (Celcius)	°F (Fahrenheit)	9/5 °C + 32	5/9 (°F-32)
°C (Celcius)	K (Kelvin)	°C + 273,15	K-273,15

miscellaneous

units		multiply by	
		→	←
atmospherd	millimeter Hg (torr)	760	1,316.10 ⁻³
atmosphere	pascal (N/m ²)	1,013.10 ⁵	9,8716.10 ⁻⁶
bar	millimeter Hg (torr)	750,1	1,331.10 ⁻³
bar	pascal (N/m ²)	10	0,1

other

units		multiply by	
		→	←
Btu	kilowatt-hour	293.10 ⁻⁶	3409,52
centimetre	foot	0,03281	30,48
centimetre cen	inch	0,3937	2,54
cubic foot	cubic metre	0,0283	35,3146
degree (angle)	radian	0,01745	57,30
foot	metre	0,3048	3,281
kilocalorie	kilowatt-hour	1,163.10 ⁻³	859,184
kilometer	mile	0,6214	1,609
metre	yard	1,094	0,9144
square foot	square metre	0,0929	10,76

ตารางแปลงอุณหภูมิ

°C	°F	°C	°F	°C	°F	°C	°F	°C	°F
-90.00	-130	-31.11	-24	-7.78	18	15.56	60	43.33	110
-87.22	-125	-30.56	-23	-7.22	19	16.11	61	46.11	115
-84.44	-120	-30.00	-22	-6.67	20	16.67	62	48.89	120
-81.67	-115	-29.44	-21	-6.11	21	17.22	63	51.67	125
-78.89	-110	-28.89	-20	-5.56	22	17.78	64	54.44	130
-76.11	-105	-28.33	-19	-5.00	23	18.33	65	57.22	135
-73.33	-100	-27.78	-18	-4.44	24	18.89	66	60.00	140
-70.56	-95	-27.22	-17	-3.89	25	19.44	67	62.78	145
-67.78	-90	-26.67	-16	-3.33	26	20.00	68	65.56	150
-65.00	-85	-26.11	-15	-2.78	27	20.56	69	68.33	155
-62.22	-80	-25.56	-14	-2.22	28	21.11	70	71.11	160
-59.44	-75	-25.00	-13	-1.67	29	21.67	71	73.89	165
-56.67	-70	-24.44	-12	-1.11	30	22.22	72	76.67	170
-53.89	-65	-23.89	-11	-0.56	31	22.78	73	79.44	175
-51.11	-60	-23.33	-10	0.00	32	23.33	74	82.22	180
-48.33	-55	-22.78	-9	0.56	33	23.89	75	85.00	185
-45.56	-50	-22.22	-8	1.11	34	24.44	76	87.78	190
-45.00	-49	-21.67	-7	1.67	35	25.00	77	90.56	195
-44.44	-48	-21.11	-6	2.22	36	25.56	78	93.33	200
-43.89	-47	-20.56	-5	2.78	37	26.11	79	96.11	205
-43.33	-46	-20.00	-4	3.33	38	26.67	80	98.89	210
-42.78	-45	-19.44	-3	3.89	39	27.22	81	101.67	215
-42.22	-44	-18.89	-2	4.44	40	27.78	82	104.44	220
-41.67	-43	-18.33	-1	5.00	41	28.33	83	107.22	225
-41.11	-42	-17.78	0	5.56	42	28.89	84	110.00	230
-40.56	-41	-17.22	1	6.11	43	29.44	85	112.78	235
-40.00	-40	-16.67	2	6.67	44	30.00	86	115.56	240
-39.44	-39	-16.11	3	7.22	45	30.56	87	118.33	245
-38.89	-38	-15.56	4	7.78	46	31.11	88	121.11	250
-38.33	-37	-15.00	5	8.33	47	31.67	89	123.89	255
-37.78	-36	-14.44	6	8.89	48	32.22	90	126.67	260
-37.22	-35	-13.89	7	9.44	49	32.78	91	129.44	265
-36.67	-34	-13.33	8	10.00	50	33.33	92	132.22	270
-36.11	-33	-12.78	9	10.56	51	33.89	93	135.00	275
-35.56	-32	-12.22	10	11.11	52	34.44	94	137.78	280
-34.44	-30	-11.11	12	12.22	54	35.56	96	143.33	290
-33.89	-29	-10.56	13	12.78	55	36.11	97	146.11	295
-33.33	-28	-10.00	14	13.33	56	36.67	98	148.89	309
-32.78	-27	-9.44	15	13.89	57	37.22	99	151.67	305
-32.22	-26	-8.89	16	14.44	58	37.78	100	152.22	306
-31.67	-25	-8.33	17	15.00	59	40.56	105	152.78	307

Metric units of weight			British and US Units of weight		British units of weight		US units of weight	
Tone (t)	kilogramme (kg)	gramme (g)	pound (lb)	ounce (oz)	ton (t)	hundredweight (cwt)	ton (t)	hundredweight (cwt)
1	1000	106	2204.6	35274	0.9842	19.685	1.1023	22.05
0.001	1	1000	2.2046	35.274	0.00098	0.0197	0.0011	0.022
0.000001	0.001	1	0.00205	0.0353	9.8e-10 ⁶	0.02e-10 ³	0.11e-10 ⁵	0.22e-10 ⁴
0.454e-10 ⁻³	0.454	453.6	1	16	0.000447	0.00893	0.0005	0.01
0.283e-10 ⁻⁴	0.0283	28.35	0.0625	1	0.279e-10 ⁻⁴	0.558e-10 ⁻³	0.312e-10 ⁻⁴	0.625e-10 ⁻³
1.016	101	1.016e-10 ⁻⁶	2240	35840	1	20	1.120	11.20
0.0508	50.802	50802	112	1792	0.5	1	0.056	1.12
0.9072	907.19	907.19	2000	32000	0.8929	17.841	1	20
0.4536	45.359	45359	100	1600	0.0446	0.8929	0.05	1

Special weights: 1 Pfund (German) = 0.5 kg
 1 carat = 200 mg (precious stones)
 1 carat = 4.166% (fine gold)
 e.g. 14 carat = 58.333% (fine gold)
 24 carat = 100% (fine gold)

1 bushel = 60 lbs = 27.216 kg (Brit. and US)

1 quarter = 25 lbs = 11.340 kg (US)

1 quarter = 28 lbs = 12.701 kg (Brit.)

1 grain (gr) = 64.8 mg (US and Brit.)

1 carat = 3.17 grains (precious stones) (Brit. And US)

ตารางที่บัญชีหน่วยเมตริก, อังกฤษ, สหรัฐฯ

metric. units of volume				British and US units of volume				US liquid measure	
cubic netre (m ³)	cubic decimeter (dm ³)	cubic centimeter (cm ³)	cubic millimeter (mm ³)	cubic yard (cuyd)	cubic foot (cuft)	cubic inch (cuin)	gallon	quart	pint
1	1000	1000·10 ⁻³	1000·10 ⁻⁶	1.3079	35.32	61·10 ⁻³	264.2	1056.8	2113.6
1·10 ⁻³	1	1000	1000·10 ⁻³	1.3079·10 ⁻³	0.03532	61·10 ⁻²	0.2642	1.0568	2.1136
1·10 ⁻⁶	1·10 ⁻³	1	1000	1.3079·10 ⁻⁶	0.3532·10 ⁻⁴	0.061023·10 ⁻⁴	0.2642·10 ⁻³	1.0568·10 ⁻³	2.1136·10 ⁻³
1·10 ⁻⁹	1·10 ⁻⁶	1·10 ⁻³	1	1.379·10 ⁻⁹	0.3532·10 ⁻⁷	0.610·10 ⁻⁴	0.2642·10 ⁻⁶	1.0568·10 ⁻⁶	2.1136·10 ⁻⁶
0.764573	764.573	764573	764573·10 ⁻³	1	27	46656	202	808	1616
0.0283170	28.31701	28317.01	28317013	0.037037	1	1728	748224	29.92896	59.85792
0.1638·10 ⁻⁴	0.0163871	16.38716	16387.16	0.2143·10 ⁻⁴	0.5787·10 ⁻³	1	0.00433	0.01732	0.03464
3.785·10 ⁻³	3.785442	3.785442	3785442	0.0049457	0.1336797	231	1	4	8
0.9463·10 ⁻³	0.9463605	946.3605	946360.5	0.0012364	0.0334199	57.75	0.250	1	2
0.4732·10 ⁻³	0.4731802	473.1802	473180.2	0.0006182	0.0167099	28.875	0.125	0.500	1

Special measures:

1 litre (l)	= 1000 cm ³	1 imp.gallon	= 4 quarts	8 pints	= 4.546 dm ³	1 bushel	= 35.242 dm ³
1 hectolite	= 100 l	1 bushel	= 8 imp.gal		= 36.3677 dm ³	1 register ton	= 100 cu.ft
1 register ton = 2.832 m ³		1 register ton = 100 cu.ft			= 2.8316 m ³	1 ocean ton	= 40 cu.ft
1 GRT	= gross register ton.	1 barrel (oil)	= 560 cu.ft		= 158.76 l	1 barrel	= 31.5 gal
						or	= 42 gal
						or	= 50 gal
							= 189.267 l

1 NRT
= net register ton,
refers only to cargo space

ตารางแปลงหน่วยของโบลต์

Fastener Diameters-ANSI-Unified Inch Vs ANSI-ISO Metric Sizes

Metric Sizes, mm	Inch Equivalent	Unified Inch Sizes
	0.060	#0
1.6	0.063	
	0.073	#1
2	0.078	
	0.086	#2
2.5	0.098	
	0.099	#3
	0.112	#4
3	0.118	
	0.125	#5
3.5	0.138	#6
4	0.158	
	0.164	#8
	0.190	#10
5	0.197	
	0.216	#12
6	0.234	
6.3	0.248	
	0.250	1/4 in.
	0.313	5/16 in.
8	0.315	
	0.375	3/8 in.
10	0.394	
	0.438	7/16 in.
12	0.472	

Metric Sizes, mm	Inch Equivalent	Unified Inch Sizes
	0.500	1/2 in.
14	0.551	
	0.536	9/16 in.
	0.625	5/8 in.
16	0.630	
	0.750	3/4 in.
20	0.784	
	0.875	7/8 in.
24	0.945	
	1.000	1 in.
	1.125	1 1/8 in.
30	1.181	
	1.250	1 1/2 in.
	1.375	1 3/8 in.
36	1.417	
	1.500	1 1/2 in.
42	1.654	
	1.750	1/34 in.
48	1.890	
	2.000	2 in.
56	2.205	
	2.250	2 1/4 in.
	2.500	2 1/2 in.
64	2.520	

$$gastond Ro = 8.3143 \text{ KJ/Kmc/K}$$

$$\text{N/M}^2 = \text{Pa}$$

$$\text{Standard Pressure } 1.013 \times 105 \text{ N/M}^2 = 101.3$$

Kpa

$$\text{M/S} = 3.28 \text{ fps}$$

$$n = (120 = f) p$$

General Metric Conversion Factors

Lengths:

1 inch	=	25.4 mm	=	0.0254 m
1 foot	=	304.8 mm	=	0.3048 m
1 yard	=	914.4 mm	=	0.9144 m
1 mile	=	1609.0 m	=	1.609 km
1 nautical mile	=	1852.0 m	=	1.852 km

Volume:

1 in ³	=	16.3871 cm ³
1 yd ³	=	0.7646 m ³
1 ft	=	0.0283 m ³

Area:

1 in ²	=	0.00064516 m ²	=	6.45 cm ²
1 ft ²	=	0.0929 m ²		
1 yd ²	=	0.836 m ²		
1 acre	=	4047.0 m ²		
1 sq. mile	=	2.5899 km ²		
1 m ²	=	1.550.0031 in ²		

Contents:

1 barrel	=	159.0 litres
1 UK gal	=	4.55 litres
1 US gal	=	3.785 litres

Temperature Conversion:

$$C = \frac{(F - 32) \times 5}{9}$$

$$F = \frac{C \times 9}{5} + 32$$

$$K = ^\circ C + 273$$

Weight:

1 lb	=	0.454 kg
1 cwt	=	50.80 kg
1 (long) ton	=	1016.0 kg
1 (short)	=	907.2 kg
1 kn	=	225 lb

Conversion Table For Pressure


1 kg/cm ²	=	0.981 bar	=	14.223 lb/in ²		1 mmHg = 1 torr
1 kg/cm ²	=	0.981 bar	=	14.223 psi		
1 kg/cm ²	=	0.981 bar	=	14.223 psig		
1 bar	=	1.0197 kbf/cm ²	=	14.503 psi		
1 bar	=	100 kPa	=	100.000 Pa (=N/m ²)	=	0.1 Mpa
1 bar	=	1000 mbar	=	750.06 mm Hg	=	29.53 in Hg
1 mbar	=	0.402 in H2O	=	100 Pa	=	0.750 mm (Hg = Torr)
1 kPa	=	0.01 bar	=	10 mbar	=	1000 Pa = 0.145 psi
1 MPa	=	1000 kPa	=	10 bar	=	10,000 mbar = 145.0 psi

Glossary of Pressure Units

kg/cm ²	=	kilograms-force per sq cm		mm Hg	=	Millimetres of mercury
kgf/cm ²	=	kilograms-force per sq cm		in Hg	=	Inches of mercury
kp/cm ²	=	Kilopound per sq cm		in H2O	=	Inches of water
lb/in ²	=	Lbs per sq inch		Torr	=	Torr
psi	=	Pound-force per sq inch		H/m ²	=	Newtons per sq metre
psig	=	pound-force per sq inch guage		kPa	=	Kilopascals
bar	=	Bar		Pa	=	Pascals
mbar	=	Millibar		MPa	=	Megapascals

$$\text{Velocity (M/S)} = \frac{\text{Flow rate (l/h)} \times 0.35344}{ID^2(\text{mm})}$$

$$\text{flow rate (l/h)} = \frac{\text{Velocity (M/S)} \times ID^2(\text{mm})}{0.35344}$$



กฎร่วม gas

$$V \propto \frac{1}{P} \quad (T, n \text{ คงที่})$$

$$V \propto T \quad (P, n \text{ คงที่})$$

$$V \propto \frac{T}{P}$$

$$PV = K$$

$$V \propto n \quad (P, T \text{ คงที่})$$

n = จำนวนโมล

Ideal gas

$$PV = nRT$$

$$R = 3.314 \text{ J mol}^{-1} \text{ K}^{-1}$$

Steam Table

p bar	t °C	v" kJ/kg	h" kJ/kg	r kJ/kg
1.0	99.6	1.694	2675	2258
1.1	102.3	1.549	2680	2251
1.2	104.8	1.428	2683	2244
1.3	107.1	1.325	2687	2238
1.4	109.3	1.236	2690	2232
1.5	111.4	1.159	2693	2226
1.6	113.3	1.091	2696	2221
1.7	115.2	1.031	2699	2216
1.8	116.9	0.9771	2702	2211
1.9	118.6	0.9288	2704	2206
2.0	120.2	0.8853	2706	2202
2.1	121.8	0.8458	2709	2197
2.2	123.3	0.8097	2711	2193
2.3	124.7	0.7767	2713	2189
2.4	126.1	0.7464	2715	2185
2.5	127.4	0.7184	2716	2181
2.6	128.7	0.6925	2718	2177
2.7	130.0	0.6684	2720	2174
2.8	131.2	0.6460	2722	2170
2.9	132.4	0.6251	2723	2167
3.0	133.5	0.6056	2725	2163
3.2	135.8	0.5700	2728	2157
3.4	137.9	0.5385	2730	2151
3.6	139.9	0.5104	2733	2144
3.8	141.8	0.4851	2735	2139
4.0	143.6	0.4623	2738	2133
4.2	145.4	0.4416	2740	2128
4.4	147.1	0.4227	2742	2122
4.6	148.7	0.4053	2744	2117
4.8	150.3	0.3894	2746	2112
5.0	151.8	0.3747	2748	2108
5.5	155.5	0.3425	2752	2096
6.0	158.5	0.3155	2756	2085
6.5	162.0	0.2925	2759	2075
7.0	164.9	0.2727	2762	2065

p bar	t °C	v" kJ/kg	h" kJ/kg	r kJ/kg
7.5	167.8	0.2555	2765	2056
8.0	170.4	0.2403	2768	2047
8.5	172.9	0.2268	2770	2038
9.0	175.4	0.2148	2772	2030
9.5	177.7	0.2040	2774	2021
10	179.9	0.1943	2776	2014
11	184.1	0.1774	2780	1999
12	188.0	0.1632	2783	1984
13	191.6	0.1511	2785	1971
14	195.0	0.1407	2788	1958
15	198.3	0.1316	2790	1945
16	201.4	0.1237	2792	1933
17	204.3	0.1166	2793	1921
18	207.1	0.1103	2795	1910
19	209.8	0.1046	2796	1898
20	212.4	0.09952	2797	1889
21	214.9	0.09488	2798	1878
22	217.3	0.09064	2799	1868
23	219.6	0.08676	2800	1858
24	221.8	0.08319	2800	1849
25	223.9	0.07990	2801	1839
26	226.0	0.07685	2801	1839
27	228.1	0.07402	2802	1821
28	230.1	0.07139	2802	1812
29	232.0	0.06893	2802	1808
30	233.8	0.06663	2802	1794
32	237.4	0.06244	2802	1777
34	240.9	0.05873	2802	1761
36	244.2	0.05542	2802	1744
38	247.3	0.05244	2801	1729
40	250.3	0.04975	2800	1713
42	253.2	0.04731	2800	1698
44	256.0	0.04508	2798	1683
46	258.7	0.04304	2797	1668
48	261.4	0.04116	2796	1654
50	263.9	0.03943	2794	1640

Pressure p (bar) is absolute

Torr	mbar
1	1.333
2	2.666
3	4.000
4	5.333
5	6.666
6	7.999
7	9.332
8	10.666
9	11.999
10	13.332

$1 \frac{N}{m^2}$	= 1	Pa
1 bar	= $1 \cdot 10^5$	$\frac{N}{m^2}$
$1 \frac{N}{m^2}$	= 0.102	$\frac{kp}{m^2}$
1 bar	= 1020	at
1 mbar	= 0750	Torr
1 kJ	= 0.2388	kcal
1 W	= 0.8598	$\frac{kcal}{h}$

1 Pa	= 1	$\frac{N}{m^2}$
$1 \frac{N}{m^2}$	= $1 \cdot 10^5$	bar
$1 \frac{kp}{m^2}$	= 9.807	$\frac{N}{m^2}$
1 at	= 0.981	bar
1 Torr	= 1.333	mbar
1 kcal	= 4.1868	kJ
$1 \frac{kcal}{h}$	= 0.8598	W

Basic Properties of Plastics

Item	Unit	Rigid PVC (UPVC)	Heat-resistant (CPVC)	Polypropylene (PP)	Vinyldene fluoride (PVDF)
Pecific gravity	-	1.43	1.5	0.92	1.78
Water absorption	mg/cm ²	0.1 and less	0.15 and less	0.01 and less	0.03 and less
Tensile strength	kgf/cm ²	500 and over	500 and over	280 and over	500 and over
Tensile strength (at 90 °C)	kgf/cm ²	-	250 and over	150 and over	250 and over
Tensile Modulus	kgf/cm ²	3×10^4	3.2×10^4	1.2×10^4	1.5×10^4
Bending strength	kgf/cm ²	900 and over	900 and over	350 and over	900 and over
Poisson's ratio	-	0.38	0.35	0.44	0.28
Charpy impact strength	kgr-cm/cm ²	7~10	4~5	7~10	18~20
Heat distortion temperature (4.6 kg f/W)	°C	74	110	105	145
Temperature limit for continuous service	°C	60	90	90	120
Linear thermal coefficient of expension	/°C	7×10^{-5}	7×10^{-5}	12×10^{-5}	12×10^{-5}
Thermal conductivity	kcal/mg°C	0.13	0.12	0.08	0.11
Electric strength	kv/mm	40 and over	40 and over	26	30
Specific volume resistance	cm	5.3×10^{15}	5.3×10^{15}	4.9×10^{15}	5×10^{15}

U.S Mesh to Micron Particle Size Conversion

U.S. Mesh	Inches	Microns	U.S. Mesh	Inches	Microns
3	.265	6730	40	0.165	420
3½	.223	5560	45	0.138	354
4	.187	4760	50	.0117	297
5	.157	4000	60	.0098	250
6	.132	3360	70	.0083	210
7	.111	2830	80	.0070	177
8	.0937	2380	100	.0059	149
10	.0787	2000	120	.0049	125
12	.0661	1680	140	.0041	105
14	.0555	1410	170	.0035	88
16	.0469	1190	200	.0029	74
18	.0394	1000	230	.0024	63
20	.0331	841	270	.0021	53
25	.0280	707	325	.0017	44
30	.0232	595	400	.0015	37
35	.0197	500			

Viscosity Conversion Chart

CPS

Temperature = 77°F

Viscosity Measurement	10	20	50	100	200	500	1000	2000	5000	10,000	20,000	10,000	20,000	50,000
Method														
ASTM, 07				72	143	357	715	1430	3750	7150	14,300	35,700		
ASTM, 10					42	104	208	417	1041	2080	4170	10,410		
ASTM, 15						24	48	95	238	476	953	2,380		
ASTM, 20						8	16	33	82	164	328	620		
ASTM, 25							7	14	36	72	143		357	
Brookfield	10	20	50	100	200	500	1000	2000	5000	10,000	20,000	10,000	20,000	50,000
Demmler #1				32	63	156	312							
Demmler #10				3	6	15	31							
Engler (degrees)				14	27	68	137	274	685	1370	2,740	6,850		
Engler (sec.)				690	1300	3460	7000	4,000	70,500	70,500				
Ford #3				42	84	208	416	834	2081	4160	8,340	20,810		
Ford #4				30	55	135	270	540	1350	2700	5,400	13,500		
Fisher #1	20	30												
Fisher #2			15	24	50									
Gardner-Holdt (units)	A-3	A-2	A	D	H	S	W	Y-2	Z3	25	26-Z7	27-28		
Gardner-Holdt (sec.)						5	10	20	50	100	200	500		
Gardner-Vertical (sec.)							5	10	20	50	100	200	500	
Krebs-Stormer (units)	85	105	140			67	85	105	140					
Parlin7				77	154	385	770	1540	3850	7700	15,400	38,500		
Parlin10				21	42	104	208	416	1040	2080	4,160	10,400		
Parlin15				10	25	47	93	232	465	930	2,320			
Parlin20						8	17	33	83	167	333	833		
Parlin25								15	36	72	143	357		
Parlin30									19	38	77	192		
Saybolt Furol			24	48	96	238	476	954	2380	4,760	9,540	23,800		
Saybolt Universal (SUS)	96	238	476	954	2380	4,760	9540	23,800	47,600	95,400				
Zahn G1	38	60	100	267	667	1332	2670	6670	13,320	26,700	66,700			
Zahn G2	16	24	42	82	161	323	645	1610	3,230	6,450	16,100			
Zahn G3				27	58	113	204	510	1,020	2,040	5,100			
Zahn G4				19	38	71	160	400	800	1,600	4,000			
Zahn G5				13	27	50	97	212	424	848	2,120			

Chemical Resistance of Material

Chemicals	Concent-ration (%)	Temper-ature	PVC (°c)	CPVC	PP	Material PVDF	PTFE	EPDM	FPM
Sodium chloride Water Solution	Saturated	40	•	•	•	•	•	•	•
		60	•	•	•	•	•	•	•
		80		•	•	•	•	•	•
Hydrochloric acid	35	40	•	•	•	•	•	•	•
		60	○	•	•	•	•	•	•
		80		○	○	●	○	○	○
Caustic soda	50	40	•	•	•	○	•	•	x
		60	•	•	•	▲	•	○	
		80		•	○	x	•	▲	
Chromic acid	20	40	•	•	x	•	•	○	•
		60	○	•		•	•	x	○
		80		○		•	•		○
Acetic acid	50	40	○	○	○	•	•	○	○
		60	▲	▲	▲	●	•		○
		80		x		○	•		▲
Soda hypochlorite	13	40	•	•	▲	•	•	x	○
		60	○	○		○	•		
		80				x	•		
Nitric acid	50	40	○	○	•	•	•	x	○
		60	○	▲	▲	•	•		▲
		80	x	▲	x	○	•		x
Toluene		40	x	x	▲	•	•	x	
		60			x	○	•		
		80				▲	•		
Hydrogen Sulfide	Aqueous Solution	40	•	•	•	•	•	•	•
		60	•	•	•	•	•	•	○
		80		•	•	•	•	•	
Sulfuric acid	90	40	○	•	•	•	•	○	•
		60	○	○	○	•	•	▲	•
		80		▲	○	•	•	x	○

• Not affected, o Negligibly affected, ▲ Slightly affected but serviceable, x Not serviceable

Reference Range of Temperature

Material	Abbreviation	General chemical resistance	Max. Service Temperatree	
			Continuous	Short Hours
Rigid Polyvinyl Chloride (Rigid PVC)	PVC	Resistant against most of acids, alkalis and salts of high to low concentration level. However, the material tends to be attacked by some chemicals – such as aromatic hydrocarbon, ketones, esters and chlorinated hydrocarbon	50C~50°C	60°C
Heat-resistant Rigid Polyvinyl Chloride (Heatresistant PVC)	CPVC	Resistance properties are nearly the same as rigid PVC. Having a hibh heatresistance, this is serviceable in the temperature range higher than the former's	00C~90°C	100°C
Polypropylene	PP	Not stable against strong acids such as Concentrated nitric acid and chrome acid mixture, but this is resistant against other acids, alkalies and salts. Resistant against many organic solvents (specifi-cally the solvent with active group), but tends to be attacked by chlorine-containing solvents, aliphatic series and aromatic hydro-carbon.	00C~90°C	100°C
Vinylidene Fluoride	PVDF	Highly resistant up to a high temperature range against ordinary acids & salts and organic chemicals, but broken down by fuming sulfuric acid and strong basic amines. Also, the use conditions with ketone, amide, ester, organic solvent ad alkali are limited.	-200C~150°C	150°C
Ethylene Propylene Rubber	EPDM	Provided with an excellent ozone-resistance and chemical-resistance. Comparatively resistant against ketone and ester, but less resistant against aromatic & aliphatic families, and gasoline and oil.	-100C~130°C	150°C
Polytetra-fluoroethylene (Trade name, Teflon®)	PTFE	Resistant against ordinary acid and alkali, and not dissolved nor changed by ordinary solvent medium. Attacked by melted alkali metal and in a high temperature, by fluorine and chlorine trifluoride.	-200C~250°C	300°C
Fluororubber (Trade name, Viton®)	FPM	Most chemical-resistant among all rubber families. Has a good resistance against strong oxidizing acid such as concentrated sulfuric acid and nitric acid; resistant against aliphatic and aromatic families and oils, but attacked by ketones, ammonia anhydride, concentrated caustic soda.. etc.	-50C~150°C	200°C

NEMA Type 1:

General purpose: intended for indoor use primarily to provide a degree of protection against contact With the enclosed parts in locations without unusual service conditions.

NEMA Type 2:

Driproof: intended for indoor use primarily to provide a degree of protection against limited amounts of falling water or dirt.

NEMA Type 3:

Raintight, dust/dust and sleet (ice) resistant: intended for outdoor use primarily to provide a degree of protection against wind blown dust, rain and sleet; undamaged by the formation of ice on the enclosure.

NEMA Type 3S:

Raintight, dusttight and sleet (ice) resistant: intended for outdoor use primarily to provide a degree of protection against wind blown dust, rain and sleet; external mechanism remains operable when ice laden.

NEMA Type 3R:

Rainproof, sleet (ice) resistant: intended for outdoor use primarily to provide a degree of protection against falling rain and sleet, undamaged by the formation of ice on the enclosure.

NEMA Type 4:

Watertight and dusttight: intended for indoor or outdoor use to provide a degree of protection against splashing water, water seepage, falling or hose directed water and severe external condensation, undamaged by the formation of ice on the enclosure.

NEMA Type 4X:

Watertight, dusttight and corrosion resistant: same as Type 4 enclosure, but provides additional protection to resist corrosion.

NEMA Type 6:

Submersible: intended for indoor or outdoor use to provide a degree of protection against entry of water during submersion at a limited depth.

NEMA Type 6P:

Submersible: same as Type 6 enclosure, but provides prolonged submersion protection at a limited depth.

NEMA Type 7(A,B,C AND D):

Explosion proof, Class 1, Division 1, Groups A, B, C and D hazardous locations: designed to contain and internal explosion without causing an external hazard when installed in the indicated atmospheres and locations. Class 1, Division 1 locations are those in which hazardous atmospheres are, or may be, present under normal operating conditions.

These enclosures are also suitable for Class 1, Division d locations in which hazardous atmospheres are present only in case of accidental rupture or breakdown of equipment, or abnormal operation. Type 1 general purpose enclosures may be permitted in a Class 1, Division 2 location subject to the approval authority. (ref: national electrical code 501-3, b3).

Group designations are described in national building code as follows:

Group A –atmospheres containing acetylene.

Group B –atmospheres containing hydrogen.

Group C –atmospheres containing ethylether vapors, ethylene or cyclopropane.

Group D –atmospheres containing gasoline, hexane, naphtha, benzene, benzol, lacquer, solvent

Vapors or natural gas.

NEMA Type 9(E,F AND G):

Dust ignitionproof, Class ii, groups E,F and G hazardous locations:

Designed to prevent the entrance of dust, and the enclosed devices do not produce sufficient heat to cause external surface temperatures capable of igniting dust on the enclosure or in the surrounding atmosphere. Class ii, Division 1 locations are those in which combustible dust is, or may be, present under normal operating conditions. These enclosures are also suitable for Class ii, Division 2 locations in which hazardous dust is present only under abnormal conditions.

The group designations are described in the national electrical code as follows:

Group E –atmospheres containing metal dust, including aluminum, magnesium their commercial alloys, and other metals of similarly hazardous characteristics.

Group F –atmospheres containing carbon black, coal or coke dust.

Group G –atmospheres containing flour, starch or grain dust.

ค่าการนำกระแสสูงสุดของสายไฟฟ้า

cable size	current capacity of 70 °C 750 V cable at 40 °C ambient temperature					
	PVC/sheathed cable in conduit		PVC/sheathed cable in conduit underground		PVC/sheathed cable direct buried underground	
	no of cable		no of cable		no of cable	
	1-3	4-6	1-3	4-6	1-3	4-6
0.5	7	6				
1	10	8	15	12	21	17
1.5	13	11	18	15	26	21
2.5	17	14	24	20	34	28
4	22	18	31	25	45	37
6	30	25	40	33	56	46
10	42	34	52	43	75	61
16	54	44	68	56	97	80
25	73	60	89	73	125	103
35	92	75	109	89	150	123
50	109	89	130	107	177	145
70	139	114	161	132	216	177
95	173	142	200	164	259	212
120	202	166	231	189	294	241
150	228	187	266	218	330	271
185	263	216	303	248	372	305
240	317	260	361	296	431	353
300	358	294	418	343	487	399
400	439	360	489	401	552	453
500	496	407	562	461	623	511

จำนวนสายสูงสุด ภายในท่อร้อยสายไฟฟ้า

cable size	conduit size									
	12.5mm 1/2 in	19 mm 3/4 in	25 mm 1 in	32 mm 1 1/4 in	38 mm 1 1/2 in	50 mm 2 in	60 mm 2 1/2 in	75 mm 3 in	90 mm 3 1/2 in	100 mm 4 in
0.5										
1	6	10	18	31	45					
1.5	5	10	14	25	35					
2.5	3	5	9	16	22	38				
4	3	5	7	13	18	30	47			
6	2	4	5	10	14	23	36	48		
10	1	3	4	6	9	15	22	32	44	50
16	1	2	3	4	5	9	14	21	28	37
25				3	4	7	11	16	22	28
35				2	3	5	8	13	18	23
50				1	2	4	6	9	13	16
70				1	1	3	5	8	10	13
95				1	1	2	3	6	8	10
120				1	1	2	3	6	8	10
150				1	1	2	3	5	7	9
185				1	1	1	2	4	5	7
240				1	1	1	1	3	4	6
300					1	1	1	3	4	5
400						1	1	1	3	4
500						1	1	1	2	3

ขนาดสาย, ท่อ, CB ตามขนาดมอเตอร์ที่ 1

output		AC three phases direct on line starter (DOL)								
kW	HP	PF	current at 380 VAC	circuit breaker	cable and conduit from starter to motor			voltage drop		
					5%	3%	2%	max distance (m)		
0.18	0.25	0.68	0.71	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			2570	15..	1030
0.25	0.35	0.71	0.92	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			1900	11..	760
0.37	0.5	0.73	1.1	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			1545	9..	620
0.55	0.75	0.74	1.6	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			1050	6..	420
0.75	1	0.74	2.1	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			800	4..	320
1.1	1.5	0.75	3.1	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			535	3..	214
1.5	2	0.78	4	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			399	2..	160
2.2	3	0.78	5.5	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			290	1..	116
3	4	0.82	6.7	3P, 15A	3-2.5/2.5 G., dia $\frac{3}{4}$ in or 19 mm			227	1..	91
4	5.5	0.81	8.8	3P, 20A	3-4/4 G., dia $\frac{3}{4}$ in or 19 mm			279	1..	112
5.5	7.5	0.85	11.6	3P, 20A	3-4/4 G., dia $\frac{3}{4}$ in or 19 mm			202	1..	81
7.5	10	0.86	14.8	3P, 30A	3-6/6 G., dia $\frac{3}{4}$ in or 19 mm			234	1..	93
11	15	0.82	23.6	3P, 50A	3-6/6 G., dia $\frac{3}{4}$ in or 19 mm			153	92	61
15	20	0.82	31	3P, 60A	3-10/6 G., dia 1 in or 25 mm			194	1..	77
18.5	25	0.85	36.5	3P, 80A	3-16/10 G., dia $1\frac{1}{4}$ in or 32 mm			254	1..	100
22	30	0.85	43.5	3P, 80A	3-16/10 G., dia $1\frac{1}{4}$ in or 32 mm			210	1..	84
30	40	0.87	58	3P, 100A	3-25/10 G., dia $1\frac{1}{2}$ in or 38 mm			240	1..	96
37	50	0.83	74	3P, 150A	3-50/16 G., dia 2 in or 50 mm			265	1..	106
45	60	0.84	89	3P, 175A	3-70/16 G., dia $2\frac{1}{2}$ in or 50 mm			288	1..	115
55	75	0.87	104	3P, 225A	3-70/35 G., dia $2\frac{1}{2}$ in or 50 mm			335	2..	134
75	100	0.88	139	3P, 250A	3-120/35 G., dia 3 in or 75 mm			330	1..	132
90	125	0.88	185	3P, 400A	3-185/35 G., dia 3 in or 75 mm			422	2..	169
110	150	0.86	209	3P, 400A	3-185/35 G., dia 3 in or 75 mm			372	2..	149
132	175	0.86	245	3P, 500A	3-240/50 G., dia $3\frac{3}{4}$ in or 90 mm			384	2..	153
160	220	0.86	300	3P, 600A	3-400/50 G., dia 4 in or 100 mm			439	2..	176
200	275	0.86	373	3P, 700A	2(3-185/35G., dia 3 in or 75 mm)			417	2..	167
220	300	0.88	400	3P, 800A	2(3-185/35G., dia 3 in or 75 mm)			390	2..	155
260	350	0.88	460	3P, 1000A	2(3-240/35G., dia $3\frac{3}{4}$ in or 90 mm)			412	2..	165
300	400	0.88	525	3P, 1000A	2(3-240/35G., dia $3\frac{3}{4}$ in or 90 mm)			419	2..	167

ขนาด สาย, ท่อ, CB ตามขนาดมอเตอร์ที่ 2

output		AC three phases direct on line starter (DOL)									
kW	HP	PF	current at 380 VAC	circuit breaker	cable and conduit from starter to motor			voltage drop			
								max distance (m)	5%	3%	2%
5.5	7.5	0.85	11.6	3P, 20A	6-4/4 G., dia 1 in or 25 mm			351	210	140	
7.5	10	0.86	14.8	3P, 30A	6-6/6 G., dia 1 $\frac{1}{4}$ in or 32 mm			405	243	162	
11	15	0.82	23.6	3P, 50A	6-6/6 G., dia 1 $\frac{1}{4}$ in or 32 mm			265	159	106	
15	20	0.82	31	3P, 60A	6-6/6 G., dia 1 $\frac{1}{4}$ in or 32 mm			202	121	81	
18.5	25	0.85	36.5	3P, 80A	6-10/10 G., dia 1 $\frac{1}{2}$ in or 38 mm			277	166	111	
22	30	0.85	43.5	3P, 80A	6-10/10 G., dia 1 $\frac{1}{2}$ in or 38 mm			232	139	93	
30	40	0.87	58	3P, 100A	6-16/10 G., dia 2 in or 50 mm			268	161	107	
37	50	0.83	74	3P, 125A	6-25/16 G., dia 2 in or 50 mm			338	203	135	
45	60	0.84	89	3P, 150A	6-35/16 G., dia 2 $\frac{1}{2}$ in or 50 mm			379	190	126	
55	75	0.87	104	3P, 175A	6-35/16 G., dia 2 $\frac{1}{2}$ in or 60 mm			316	190	126	
75	100	0.88	139	3P, 225A	6-70/35 G., dia 3 in or 75 mm			432	259	173	
90	125	0.88	185	3P, 300A	6-95/35 G., dia 3 $\frac{1}{2}$ in or 88 mm			430	258	172	
110	150	0.86	209	3P, 400A	6-120/35 G., dia 3 $\frac{1}{2}$ in or 88 mm	465		279	186		
132	175	0.86	245	3P, 400A	6-150/35 G., dia 3 $\frac{1}{2}$ in or 88 mm	466		280	186		
160	220	0.86	300	3P, 500A	6-185/50 G., dia 4 in or 100 mm			449	269	179	
160	220	0.86	300	3P, 500A	6-150/50 G., in wireway 200 mm (option)			381	228	152	
200	275	0.86	373	3P, 600A	6-240/50 G., in wireway 200 mm			436	261	175	
220	300	0.88	400	3P, 700A	6-240/70 G., in wireway 200 mm			338	202	135	
260	350	0.88	460	3P, 800A	6-300/70 G., in wireway 300 mm			345	207	138	
300	400	0.88	525	3P, 1000A	6-400/70 G., in wireway 300 mm			368	220	147	

ตารางแสดงขนาดสาย, ท่อ และ CB ตามขนาดมิเตอร์ไฟฟ้า

kWh meter	max load	CB rating	cable in conduit		cable in wireway	
			cable (mm ²)	conduit (in)	cable (mm ²)	wireway (mmxmm)
1 P, 15(45) A	30 A	2 P, 50 A	2-16/6 G	1		
1 P, 30(100) A	75 A	2 P, 100 A	2-50/10 G	2		
1 P, 50(150) A	100 A	2 P, 125 A	2-70/16 G	2		
3 P, 15(45) A	30 A	3 P, 50A	4-2516 G	2	4-16/6 G	50x50
3 P, 30(100) A	75 A	3 P, 100 A	4-70/10 G	2	4-50/10 G	100x100
3 P, 50(150) A	100 A	3 P, 125 A	4-95/16 G	2 น	4-70/16 G	100x100
3 P, 200 A	200 A	3 P, 250 A	4-240/35 G	3	4-185/35 G	100x100
3 P, 400 A	400 A	3 P, 500 A	2x(4-185/25 G)	2x4	2x(2-185/25 G)	200x100

สายติดตามขนาด CB

max rating of CB (AT)	ground conductor (sq mm)
15	2.5
20	4
30-60	6
100	40
200	16
400	35
600	50
800-100	70
1200	95
1600	120
2000	150
2500	185
3000	240
4000	300
5000	400
6000	500

คุณสมบัติของหลอดไฟ

	คุณสมบัติ	หลอดไส้	halogen	SL	PL	fluorescent	high pressure mercury (self ballast)	high pressure mercury	high pressure mercury	metal halide sodium	low pressure mercury	high pressure mercury
luminous flux lm	250 to 40000	10000 to 45000	450 to 1200	400 to 900	150 to 5300	3100 to 14000	2000 to 125000	19000 to 187000	18000 to 33000	33000 to 130000	3300 to 130000	3300 to 130000
efficacy lm/W (without ballast)	10 to 20	22	41 to 50	59 to 78	38 to 91	19 to 28	40 to 63	75 to 95	100 to 183	70 to 130	70 to 130	70 to 130
rating W light colour	25 to 2000	500 to 2000	9 to 25	7 to 11	4 to 65	160 to 500	50 to 2000	250 to 2000	18 to 180	50 to 1000	warm-white	warm-white
colour rendering	excellent	excellent	good	good	excellent to moderate	moderate	moderate	moderate	non-existent	poor	good	good
ballast	none	none	built-in	choke	choke	none	choke	choke	hybrid	choke	ignitor	ignitor
starter/ignitor	none	none	built-in	built-in	starter or starterless	none	none	separate or built-into ballast				
run-up time min	zero	zero	zero	zero	zero	zero	zero to 2	3	3	10	5	5
restrike time min	zero	zero	zero	zero	zero	5	5	10	2	2	<1	<1

ค่าความเข้มของแสงสำหรับงานลักษณะต่างๆ

	ความเข้ม ของแสง (lux)	ความเข้ม ของแสง (lux)
บริเวณทั่วไปในอาคาร		
circulation areas, corridors	100	
stairs. Escalators	150	
cloak rooms, toilets	150	
stores, stockrooms	150	
บริเวณประกอบอุปกรณ์		
rough work: heavy machinery assembly	300	
medium work: engine assembly,	500	
vehicle body assembly		
fine work: electronic and office	750	
machinery assembly		
very fine work: instrument assembly	1500	
บริเวณงานเคมี		
General interior plant areas	300	
automatic processes	150	
control rooms, laboratories	500	
pharmaceutical manufacture	500	
inspection	750	
colour matching	1000	
rubber tyre manufacturing	500	
โรงงานเสื้อผ้าสานเจริญปุ่ม		
sewing	750	
inspection	1000	
pressing	500	
อุตสาหกรรมไฟฟ้า		
cable manufacturing	300	
assembly of telephone sets	500	
winding assembly	750	
assembly of radio and television receivers	1000	
assembly of ultra-precision parts, electronic components	1500	
อุตสาหกรรมไฟฟ้า		
general working areas	300	
automatic processes	200	
hand decorating, inspection	500	
งานหล่อโลหะ		
foundry bays	200	
rough moulding, rough core making	300	
fine moulding, core making, inspection	500	
อุตสาหกรรมแก้ว		
furnace rooms	150	
mixing rooms, forming, moulding, kiln rooms	300	
finishing, enameling, glazing	500	
colouring, decorating	750	
grinding, lenses and crystal glassware, fine work	1000	
อุตสาหกรรมเหล็ก		
production plants not requiring manual intervention	100	
production plants requiring occasional intervention	150	
permanently occupied work stations in production plants	300	
control platforms and inspection	500	
อุตสาหกรรมเครื่องหนัง		
general working areas	300	
pressing, cutting, sewing, shoe production	750	
grading, matching, quality control	1000	
งานเครื่องกล		
casual work	200	
rough bench and machine work, welding	300	
medium bench and machine work, ordinary automatic machines	500	
fine bench and machine work, fine automatic machines, inspection and testing	750	
very fine work, gauging and inspection of small intricate parts	1500	

	ความเข้ม ของแสง (lux)	ความเข้ม ของแสง (lux)
งานสี		
dipping, rough spraying	300	
ordinary painting, spraying and finishing	500	
fine painting, spraying and finishing	750	
retouching and matching	1000	
โรงงานกระดาษ		
paper and board making	300	
automatic processes	200	
inspection, sorting	500	
งานพิมพ์		
Printing machine room	500	
composing rooms, proof reading	750	
precision proofing, retouching, etc.	1000	
colour reproduction and printing	1500	
steel and copper engraving	2000	
bookbinding	500	
trimming, embossing	750	
อุตสาหกรรมผิ่งทอ		
bale breaking, carding, drawing	300	
spinning, winding, reeling, combing,	500	
dyeing		
beaming, spinning (fine counts),	750	
twisting, weaving		
sewing, burling, inspection	1000	
งานไม้		
saw mills	200	
bench work, assembly	300	
wood machining	500	
finishing, final inspection	750	
สำนักงาน		
general offices, typing, computer rooms	500	
deep-plan general offices	750	
drawing offices	750	
conference rooms	500	
สถานศึกษา		
classrooms, lecture theatres		300
laboratories, libraries, libraries, reading rooms,		500
art rooms		
ร้านค้าและศูนย์แสดงสินค้า		
conventional shops		300
self-service shop		500
supermarkets		750
show rooms		50
museums and art galleries:		
light-sensitive exhibits		150
exhibits insensitive to light		300
อาคารสาธารณะทั่วไป		
cinemas		
auditorium		50
foyer		150
theatres and concert halls		100
auditorium		
foyer		200
sacred buildings		
nave		100
choir		150
บ้านและโรงเรือน		
home:		
bedrooms		
general		50
bed-head		200
bathrooms		
general		100
shaving, make-up		500
living-rooms		
general		100
reading, sewing		500
stairs		100
kitchens		
general		300
working areas		500

	ความเข้ม ของแสง (lux)	ความเข้ม ของแสง (lux)
work room	300	
nursery	150	
hotels:		
entrance halls	300	
dining rooms	200	
kitchens	500	
bedrooms, bathrooms		
general	100	
local	300	
โรงพยาบาล		
wards		
general lighting	100	
examination	300	
reading	200	
circulation at night	5	
examination rooms		
general lighting	500	
local inspection	1000	
intensive therapy		
bedhead	50	
observation	750	
nurses' stations		300
operating theatres		
general lighting	500	
local	30000	
autopsy rooms		
general lighting	750	
local	10000	
laboratories and pharmacies		
general lighting	500	
local	750	
consulting rooms		
general lighting	500	
local	750	

การคำนวณ Heat transfer และสูตร Heat load

Heat Transmission

- $Q_s = m \cdot Cp \cdot \Delta T$
 $Q_r = m \cdot \Delta H$
 $m = \text{weight of air, lb}$
 $C_p = 0.24, \text{ specific heat of dry air, Btu/lb da}$
 $\Delta T = T_{\text{room}} - T_{\text{supply air}}, T_r - T_s, {}^{\circ}\text{F}$
 $\Delta H = \text{enthalpy, } H_{\text{mix air}} - H_{\text{supply air}}, H_m - H_s, \text{ Btu/lb da}$

Room Sensible Heat, Q_{s_R} , Btu/hr

$$Q_s = 1.08 \text{ CFM}_t (T_r - T_s) \text{ Btu/hr}$$

Total Latent Heat, Q_{L_T} , Btu/hr

$$\begin{aligned}
 Q_{L_T} &= 4840 \text{ CFM}_t \Delta W \text{ btu/hr} \\
 &= 0.68 \text{ CFM}_t \Delta G \text{ Btu/hr} \\
 \Delta W &= \text{humidity ratio, } W_m - W_s, \text{ lb/lb da} \\
 \Delta G &= \text{humidity ratio, } G_m - G_s, \text{ grain/lb da}
 \end{aligned}$$

Total Heat, Q_t , Btu/hr

$$\begin{aligned}
 Q_t &= Q_{s_R} + Q_{L_T} + Q_{TOA} \\
 &= 4.5 \text{ CFM}_t \Delta H_t \\
 Q_{TOA} &= 45 \text{ CFM}_{OA} \Delta H_{OA} \\
 H_t &= H_m - H_s, \text{ Btu/lb da} \\
 H_{OA} &= H_{OA} - H_r, \text{ Btu/lb da}
 \end{aligned}$$

Subscript s at supply air condition

Subscript r at room condition

Subscript m at mixed air condition

Subscript oa at outside air condition

Subscript t means total

Room Sensible Heat Ratio

$$\begin{aligned}
 \text{SHR} &= \frac{Q_{s_R}}{Q_{T_R}} \\
 &= \frac{Q_{s_R}}{Q_{T_R} + Q_{L_T}} \\
 &= 0.24 \frac{\Delta T}{\Delta H_r} \\
 &= 0.24 \frac{T_r - T_s}{H_r - H_s}
 \end{aligned}$$

Mixed Air CFM, CFM_m

$$\begin{aligned}
 DFM_t &= \text{CFM}_{RET} + \text{CFM}_{OA} \\
 \text{CFM}_{RET} &= \text{return air CFM}
 \end{aligned}$$

Mixed Air Temp, $T_m, {}^{\circ}\text{F}$

$$\begin{aligned}
 T_m &= T_r + (T_{OA} - T_r) \frac{\text{CFM}_{OA}}{\text{CFM}_t} \\
 T_m &= T_{OA} - (T_{OA} - T_r) \frac{\text{CFM}_{RET}}{\text{CFM}_t}
 \end{aligned}$$

การคำนวณ Heat transfer และสูตร Heat load (ต่อ)

Supply Air for Cooling, CFM_T

$$CFM_T = \frac{Q_{S_R}}{1.08 (T_R - T_S)}$$

Supply Air for Dehumidification, CFM_T

$$CFM_T = \frac{Q_{L_R}}{4840 (W_R - W_S)}$$

$$= \frac{Q_{L_R}}{0.68 (G_R - G_S)}$$

Require Ventilating CFM, CFM_V

$$CFM_T = \frac{\text{cu ft room vol} \times \text{no. of air change per hour}}{60}$$

Maximum Moisture Content of Supply Air

$$W_S = W_R - \frac{Q_{L_R}}{4840 CFM_T}$$

$$G_S = G_R - \frac{Q_{L_R}}{0.68 CFM_T}$$

W_S = humidity ratio, supply air, lb_w/lb da

W_R = maximum desired room humidity ratio, lbw/lb da

Q_{L_R} = room latent heat, Btuh

CFMT = primary air supply to room

G_S = humidity ratio, supply air, grain/lb da

G_R = maximum desired room humidity ratio, grain/lb da

Coil Condensate Water (W_{cond}), h/gallon/hr

$$(W_{cond}) = \frac{4.5 CFM_T \Delta G}{7000 \times 8.33}$$

$$= \frac{CFM_T \Delta G}{12957.7} \quad \text{gallon / hr}$$

CFM = air flow through coil

$\Delta G = G_m - G_s$ G_m = humidity ratio of air at entering condition, grain/lb da

G_s = humidity ratio of air at leaving condition, grain/lb da

Condensing Water Require (W)

$$W = \frac{Q}{500 (t_2 - t_1)}$$

W = volume of condensing water, GPM

Q = heat to be removed in condenser, Btuh

t_1 = temp of water entering condenser, °F

t_2 = temp of water leaving condenser, °F

ตารางคำนวณค่า U

Conductivity (K)

Represent the Btu that will be transmitted through one square foot of the wall (or surface) In one hour if there is a temperature difference on one degree F, if the material is one-inch thickness (unit Btu/hr-sq ft - °F - in)

Conductance (C), Btu/hr - sq

It is used to indicate heat transfer through a wall made of difference substance

$$C = \frac{K}{X} \cdot \frac{1}{C} = \frac{X}{K}$$

X = thickness of material in inches

Thermal Resistance (R)

It is the resistance to heat transfer

$$R = \frac{1}{C} = \frac{1}{C_1} + \frac{1}{C_2} + \frac{1}{C_3} + \dots$$
$$= \frac{1}{U}$$

Overall Coefficient of Heat Transfer (U) Btu/hr-sq ft-°F

It is the rate of heat transfer from one side to the other side of substance.

For Flat Plate

$$U = \frac{1}{\frac{1}{f_0} + \frac{X_1}{K_1} + \frac{X_2}{K_2} + \frac{1}{C_1} + \frac{1}{C_2} + C_A + \frac{1}{f_1}}$$

f_0 = outside air film, Btu/hr-sq ft

X = thickness of material in inches

K = conductivity of material, Btu/hr-sq ft-°F-in

C = conductance of material, Btu/hr-sq ft-°F

C_A = air space conductance in Btu/hr-sq ft-°F

f_1 = inside air film, Btu/hr-sq ft

For Round Pipe

$$U = \frac{1}{\frac{1}{f_1} + \frac{R_s/n}{R_1} + \frac{R_s/n}{R_2} + \frac{R_s/n}{R_3} + \frac{1}{f_0}}$$

f_1 = conductance of inside film, Btu hr-sq ft

f_0 = conductance of outside film, Btu hr-sq ft

R_s = outer radius of outermost insulation, inch

R₁ = inner radius of innermost insulation, inch

R₂ = inner radius of the material from innermost one, ft

K₁ = conductivity of innermost material, Btu hr-sq ft-°F-in

K₂ = conductivity of the next material from innermost one

Heat Flow (Btu/hr)

Q = U.A.ΔT

U = overall coefficient of heat transfer Btu hr-sq ft-°F

A = heat transfer area, sq ft

ΔT = temp difference between higher and lower temp surface, °F

ตารางวัสดุ สำหรับผู้สนใจฯ ของอาคาร

description	density (lb/ft ³)	conductivity (k)	conductance (c)	resistance(R) Per inch thickness (1/k)	customary thickness listed (1/c)	specific heat, Btu/lb (deg F)	W lb ft	heat capacity Btu ft ² , F	Btu ft ² , F
-building board									
-boards, panels, subflooring, sheathing									
-woodboard panel products									
asbestos-cement board	120	4.0	-	0.25	-	0.24	1.25	-	-
asbestos-cement board (0.125 in)	120	-	33.00	-	0.03	2.5	0.60	0.30	28.80
asbestos-cement board (0.25 in)	120	-	16.50	-	0.06	1.56	0.41	0.41	28.80
gypsum or plaster board	50	-	3.10	-	0.32	0.26	2.08	0.54	13.00
gypsum or plaster board (0.5 in)	50	-	2.22	-	0.45	0.45	2.6	0.68	13.00
gypsum or plaster board (0.625 in)	50	-	1.78	-	0.56	-	-	-	9.86
plywood (douglas fir)	34	0.80	-	1.25	-	0.29	0.71	0.21	9.86
plywood (douglas fir) (0.25 in)	34	-	3.20	-	0.31	-	1.06	0.31	9.86
plywood (douglas fir) (0.375 in)	34	-	2.13	-	0.47	-	1.42	0.41	9.86
plywood (douglas fir) (0.5 in)	34	-	1.6	-	0.62	-	1.77	0.51	9.86
plywood (douglas fir) (0.625 in)	34	-	1.29	-	0.77	-	-	-	9.86
plywood or wood panels (0.75 in)	34	-	1.07	-	0.93	0.29	2.13	0.62	9.86
vegetable fiber board									
sheathing, regular density (0.5 in)	18	-	0.76	-	1.32	0.31	0.75	0.23	5.58
sheathing, intermediate density (0.78/125 in)	18	-	0.49	-	2.06	-	1.17	0.36	5.58
nail-base sheathing (0.5 in)	22	-	0.82	-	1.22	0.31	0.92	0.28	6.82
shingle backer (0.375 in)	18	-	0.88	-	1.14	0.31	1.04	0.32	7.75
shingle backer (0.3125 in)	18	-	1.06	-	0.94	0.31	0.56	0.17	5.58
sound deadening board (0.5 in)	15	-	0.74	-	1.35	0.30	0.62	0.19	4.50
tile and lay-in panels, plain or acoustic (0.5 in)	18	0.40	-	2.50	-	0.14	-	-	2.52
tile and lay-in panels, plain or acoustic (0.75 in)	18	-	0.80	-	1.25	0.75	0.75	0.11	2.52
laminated paper board	30	0.50	-	0.53	-	1.89	1.13	0.16	2.52
homogeneous board from						2.00	-	0.33	-
									9.90

repulped paper	30	0.50	-	2.00	-	0.28	-	-	8.40
hardboard									
medium density	50	0.73	-	1.37	-	0.31	-	-	17.60
high density, service temp service underlayment	55	0.82	-	1.22	-	0.32	-	-	17.60
high density, std tempered particleboard	63	1.00	-	1.00	-	032	-	-	20.16
low density	37	0.54	-	1.85	-	0.31	11.47		
medium density	50	0.94	-	1.06	-	0.31	15.50		
high density	62.5	1.18	-	0.85	-	0.31	19.38		
underlayment	(0.625 in)	40	-	1.22	-	0.82	0.29	2.08	0.6
wood subfloor	(0.75 in)		-	1.06	-	0.94	0.33	2.00	0.6
-building membrane									
vapor-permeable felt	-	-	16.70	-	0.06	-	-	-	-
vapor-seal, 2 layers of mopped 15-lb felt	-	-	8.35	-	0.12	-	-	-	-
vapor-seal, plastic film	-	-	-	-	negl	-	-	-	-
-finish flooring materials									
carpet and fibrous pad	-	-	0.48	-	2.08	0.34	-	-	-
carpet and rubber pad	-	-	0.81	-	1.23	0.33	-	-	-
cork tile	(0.125 in)	-	3.60	-	0.28	0.48	-	-	-
terrazzo	(1 in)	-	12.50	-	0.08	0.19	11.7	2.22	26.60
tile-asphalt, linoleum, vinyl, rubber	-	-	20.00	-	0.05	0.30	-	-	-
vinyl asbestos						0.24	-	-	-
ceramic						0.19	-	-	-
wood, hardwood finish	(0.75 in)		1.47		0.68	2.81	0.84	13.50	
-insulating materials									
-blanket and batt									
mineral fiber, fibrous form processed from rock, slag, or glass									
approx. 2-2.75 in	0.3-2.0	-	0.143	-	7	0.17-0.23	.12-.40	.02-.09	0.1-0.46
approx. 3-3.5 in	0.3-2.0	-	0.091	-	11		.16-.54	.03-.12	0.1-0.46
approx. 3.50-6.5	0.3-2.0	-	0.053	-	19		.30-.98	.05-.23	0.1-0.46
approx. 6-7 in	0.3-2.0	0.045		22		30-1.10	.05-.25	0.1-0.46	
approx. 8.5 in	0.3-2.0	0.033		30		.40-1.42	.07-.32	0.1-0.46	
-board and slabs									
cellular glass	8.5	0.38	-	2.63	-	0.24	-	-	2.64

ตารางวัสดุ สีหัวรับส่วนต่างๆ ของอาคาร (ต่อ)

description	density (lb/ft ³)	conductivity (k)	conductance (c)	resistance(R) Per inch thickness (1/k)	For thickness listed (1/c)	customary unit	specific heat, Btu/(lb (deg F))	heat capacity Btu ft ² , F
glass fiber, organic bonded	4.9	0.25	-	4.00	-	0.23	-	9.21
expanded rubber (rigid)	4.5	0.22	-	4.55	-	0.40	-	1.8
expanded polystyrene extruded cut cell surface	1.8	0.25	-	4.00	-	0.29	-	0.52
expanded polystyrene extruded smooth skin surface	2.2	0.20	-	5.00	-	0.29	-	0.64
expanded polystyrene extruded smooth skin surface	3.5	0.19	-	5.26	-	-	-	1.02
expanded polystyrene, molded beads	1.0	0.28	-	3.57	-	0.29	-	-
expanded polyurethane (R-11 exo) (thickness 1 in. or greater)	1.5	0.16	-	6.25	-	0.38	-	0.57
mineral fiber with resin binder	15	0.29	-	3.45	-	0.17	-	9.15
mineral fiberboard, wet felted core or roof insulation	16-17	0.34	-	2.94	-	-	-	2.2-2.4
acoustical tile	18	0.35	-	2.86	-	0.19	-	-
acoustical tile	21	0.37	-	2.70	-	-	-	2.94
mineral fiberboard, wet molded acoustical tile	23	0.42	-	2.38	-	0.14	-	-
wood or cane fiberboard acoustical tile (0.5 in.)	-	-	0.80	-	1.25	0.31	-	-
acoustical tile (0.75 in.)	-	-	0.53	-	-	1.89	-	-
interior finish (plank tile)	15	0.35	-	2.86	-	0.32	-	-
wood shredded (cemented in performed slabs)	22	0.60	-	1.67	-	0.31	-	4.80
loose fill								6.82
cellulosic insulation (milled paper or wood pulp)	2.3-3.2	0.27-0.32	-	3.13-3.70	-	0.33	-	.76-1.06
sawdust or shavings	8.0-15.0	0.45	-	2.22	-	0.33	-	2.64-4.45
wood fiber, softwoods	2.0-3.5	0.30	-	3.33	-	0.33	-	.66-1.16
perlite, expanded	5.0-8.0	0.37	-	2.70	-	0.26	-	1.3-2.08

mineral fiber (rock, slag or glass)					11	0.17	0.2-71	.04-.12	0.1
approx 3.75-.5 in	0.6-2.0	-							
approx 6.5-8.75 in	0.6-2.0	-			19		51-1.27	.06-.22	0.1-.34
approx 7.5-10 in	0.6-2.0	-			22		45-1.46	.07-.25	0.1-.34
approx 10.25-13.75 in	0.6-2.0	-			30		60-2.02	.1-.34	0.1-.34
vermiculite, exfoliated	7.0-8.2	.47	-	2.13	-	320	-	-	1.4-1.64
	4.0-6.0	0.44	-	2.27	-	-	-	-	0.8-1.2
roof insulation									
prefomed, for use above deck									
different roof insulations are available									
in different thicknesses to provide the design C values listed									
consult individual manufacturers for actual thickness of their material									
-masonry materials									
-concretes									
cement mortar	116	5.0	-	0.20	-	-	-	-	23.2
gypsum-fiber concrete 87.5% gypsum, 12.5% wood chips	15	1.66	-	0.60	-	0.21	-	-	10.71
lightweight aggregates including expanded shale, clay or slate; expanded slags; cinders; pumice; vermiculite; also cellular concretes	120	5.2	-	0.19	-	-	-	-	24.0
	100	3.6	-	0.28	-	-	-	-	20.0
	80	2.5	-	0.40	-	-	-	-	16.0
	60	1.7	-	0.59	-	-	-	-	12.0
perlite, expanded	40	1.15	-	0.86	-	-	-	-	8.0
	30	0.90	-	1.11	-	-	-	-	4.0
	20	0.70	1.43			-	-	-	4.0
	40	0.93	1.08			-	-	-	12.8
sand and gravel or stone aggregate (oven dried)	30	0.71	1.41			-	-	-	9.6
	20	0.50	2.00	0.32		-	-	-	6.4
sand and gravel or stone aggregate (not dried)	140	9.0	-	0.11	0.22	-	-	-	30.8
stucco masonry units	116	5.0	-	0.20	0.22	-	-	-	28.0
						-	-	-	23.2

ตารางวัสดุ สำหรับงานท่อฯ ของอาคาร (ต่อ)

description	density (lb/ft ³)	conductivity (k)	conductance (c)	resistance(R) Per inch thickness (1/k)	For listed thickness (1/c)	customary unit heat, Btu lb/ft ² , F	specific heat, Btu lb/ft ² , F	heat capacity Btu ft ² , F
brick, common	120	5.0	-	0.20	-	0.19	-	- 22.8
brick, face	130	9.0	-	0.11	-	-	-	- 24.7
clay tile, hollow :								
1 cell deep	(3 in)	-	-	125	-	0.80	0.21	15.0
1 cell deep	(4 in)	-	-	0.90	-	1.11	-	16.0
2 cell deep	(6 in)	-	-	0.66	-	1.52	-	25.0
2 cell deep	(8 in)	-	-	0.54	-	1.85	-	30.0
2 cell deep	(10 in)	-	-	0.45	-	2.22	-	35.0
3 cell deep	(12 in)	-	-	0.40	-	2.5	-	40.0
concrete blocks, three oval core:								
sand and gravel aggregate	(4 in)	-	-	1.40	-	0.71	0.22	23.0
	(8 in)	-	-	0.90	-	1.11	-	43.0
	(12 in)	-	-	0.78	-	1.28	-	63.0
cinder aggregate	(3 in)	-	-	1.16	-	0.86	0.21	17.0
	(4 in)	-	-	0.90	-	1.11	-	20.0
	(8 in)	-	-	0.58	-	1.72	-	37.0
	(12 in)	-	-	0.53	-	1.89	-	53.0
lightweight aggregate	(3 in)	-	-	0.79	-	1.27	0.21	15.0
(expanded shale, clay, slate or slag; pumice)	(4 in)	-	-	0.67	-	1.50	-	17.0
	(8 in)	-	-	0.50	-	2.00	-	32.0
	(12 in)	-	-	0.44	-	2.27	-	43.0
concrete blocks, rectangular core								
sand and gravel aggregate								
2 core, 8 in. 36 lb.	-	-	0.96	-	1.04	0.22	43.1	9.5
same with filled cores	-	-	0.52	-	1.93	0.22	-	-
lightweight aggregate (expanded shale, clay, slate or slag, pumice)								
3 cor. 6 in. 19 lb	-	-	0.61	-	1.65	0.21	22.8	4.8
Same with filled cores	-	-	0.33	-	2.99	-	-	-
2 core, 8 in. 24 lb	-	-	0.46	-	2.18	-	28.8	6.0
								9.1

same with filled cores	-	-	0.20	-	5.03	-	-	-
3 cor, 12 in. 38 lb	-	-	0.40	-	2.48	-	45.6	9.6
same with filled cores	-	-	0.17	-	5.82	-	-	-
stone, lime or sand	-	12.50	-	0.08	-	0.19	-	28.5
gypsum partition tile:								
3x12x30 in. solid	-	-	0.79	-	1.26	0.19	11.0	2.1
3x12x30 in. 4-cell	-	-	0.74	-	1.35	-	9.0	1.7
4x12x30 in. 3-cell	-	-	0.60	-	1.67	-	13.0	2.5
•plastering materials								
cement plaster, sand aggregate	116	5.0	-	0.20	-	0.20	-	-
sand aggregate (0.375 in)	-	-	13.3	-	0.08	0.20	3.63	0.72
sand aggregate (0.75 in)	-	-	6.66	-	0.15	0.20	7.25	1.45
gypsum plaster:								
lightweight aggregate (0.5 in)	45	-	3.12	-	0.32	-	1.88	0.38
lightweight aggregate (0.625 in)	45	-	2.67	-	0.39	-	2.34	0.47
lightweight agg. On metal lath (0.75 in)	-	-	2.13	0.47	-	-	0.57	-
perlite aggregate	45	1.5	-	0.67	-	0.32	-	-
sand aggregate	105	5.6	-	0.18	-	0.20	-	21.0
sand aggregate (0.5 in)	105	-	11.10	-	0.09	-	4.38	0.88
sand aggregate (0.625 in)	105	-	9.10	-	0.11	-	5.47	1.09
sand aggregate on metal lath(0.75 in)	-	-	7.70	-	0.13	-	1.32	-
vermiculite aggregate	45	1.7	-	0.59	-	-	-	9.0
•roofing								
asbestos-cement shingles	120	-	4.76	-	0.21	0.24	-	-
asphalt roll roofing	70	-	6.50	-	0.15	0.36	-	25.2
asphalt shingles	70	-	2.27	-	0.44	0.30	-	-
built-up roofing (0.375 in)	70	-	3.00	-	0.33	0.35	2.19	0.73
slate (0.5 in)	-	-	20.00	-	0.05	0.30	-	-
wood shingles, plain and plastic film faced	-	-	1.06	-	0.94	0.31	-	-
•siding materials (on flat surface)								
shingles								
asbestos-cement	120	-	4.75	-	0.21	-	-	28.8
wood, 16 in. 7.5 exposure	-	-	1.15	-	0.87	0.31	-	-

ตารางวัสดุ สำหรับงานท่อฯ ของอาคาร (ต่อ)

description	density (lb/ft ³)	conductivity (k)	conductance (c)	resistance(R) Per inch thickness (1/k)	For listed (1/c)	customary unit heat, Btu lb/ft ² , F	heat capacity Btu ft ² , F
wood, double, 16-in., 12-in exposure	-	-	0.84	-	1.19	0.28	-
wood, plus insul backer board	-	-	0.71	-	1.40	0.31	-
0.3125 in siding							
asbestos-cement, 0.25 in., lapped	-	4.76	-	0.21	0.24	-	29.5
asphalt roll siding	-	6.50	-	0.15	0.35	-	24.5
asphalt insulating siding (0.5 in bed)	-	0.69	-	1.46	0.35	-	-
wood, drop, 1 x 8 in	-	1.27	-	0.79	0.28	-	-
wood, bevel, 0.5 x 8 in., lapped	-	1.23	-	0.81	0.28	-	-
wood, bevel, 0.75 x 10 in., lapped	-	0.95	-	1.05	0.29	-	-
wood, plywood, 0.375 in., lapped	-	1.59	-	0.59	0.28	-	-
wood, medium density siding, 0.4375 in	40	1.49	-	0.67	0.28	-	11.5
aluminum or steel, over sheathing	-	-	1.61	-	0.61	0.29	-
hollow-backed insulating-board backed nominal 0.375 in	-	-	0.55	-	1.82	0.32	-
insulating-board backed nominal 0.375 in., foil backed	-	0.34			2.96	-	-
architectural glass	-	-	10.00	-	0.10	0.20	-
woods							
maple, oak, and similar hardwoods	45	1.10	-	0.91	-	0.30	-
fir, pine, and similar softwoods	32	0.80	-	1.25	-	0.33	-
fir, pine, and similar softwoods (1.5 in)	-	0.53	-	1.89	-	4.0	1.32
fir, pine, and similar softwoods (2.5 in)	-	0.32	-	3.12	-	6.7	2.20
fir, pine, and similar softwoods (3.5 in)	-	0.23	-	4.35	-	9.3	3.08

CALIBRATION SCOPE (ขอบข่ายการให้บริการสอบเที่ยบ)

Parameter	Description	Range
	Temp & Humidity Thermo-hygrometer Thermo-hygograph Temperature & Humidity Data Logger Wall Thermometer Heat Stress Meter	- 40 to 60 °C 11.3 to 90 %RH
	Temperature Source Dry Block Calibrator Temperature Bath Calibrator	- 40 to 1200 °C
	Temperature RTD Sensor Thermocouple Sensor (TC) Temperature Controller Temperature Controller with Sensor Temperature Indicator Temperature Indicator with Sensor Temperature Recorder Temperature Recorder with Sensor Temperature Transmitter Temperature Transmitter with Sensor Digital Thermometer Digital Thermometer with Sensor Temperature Gauge Liquid in Glass Thermometer Industrial Glass Thermometer Infrared Thermometer	- 40 to 1200 °C
	Temperature Enclosure Incubator / Hot Air Oven Water Bath / Liquid Bath Autoclave Freezer / Refrigerator Cold Room Furnace Temperature & Humidity Chamber	- 40 to 200 °C up to 1100 °C 10 to 60 °C 20 to 85% RH

	Electrical Control Valve Controller Indicator Recorder Transmitter Counter Stop Watch / Timer Stroboscope Photo & Contact Tachometer Centrifuge	Voltage / Current Frequency / Pulse
	Moisture Moisture Analyzer Moisture Balance Water Activity Meter	Mass & Temperature 0 to 100 %MC 0 to 1 Aw
	Analysis pH Meter pH Transmitter Conductivity Meter Conductivity Transmitter TDS Meter (Total Dissolved Solids) Lactometer Hydrometer Hand Refractometer Salinometer / Salt Meter	STD Buffer: 1.68 pH to 10 pH Simulate : 0 to 14 pH STD Buffer: 10 µS/cm to 111.8 mS/cm Simulate : 0 to 200 mS/cm 55.9, 40.0, 2.50, 0.7065, 0.042 PPT (1.02 - 1.04) SG Density (500 to 2000) kg/m³ Specific Gravity (0.50 to 2.0) SG (0 to 70°) Baume (-1 to 101) API (0 to 100) %Vol (0 - 70) % Brix (0 - 26) % Salt
	Gas Analyzer Oxygen Analyzer Methane Analyzer Dissolved Oxygen Meter	1%O₂, 21%O₂ 40%CH₄, 80%CH₄ 0 mg/l, 6 mg/l to 13 mg/l

CALIBRATION SCOPE (ข้อมูลการให้บริการสอบเที่ยบ)

Parameter	Description	Range
	Liquid Flow Meter <i>LAB : Gravimetric Method, Water Media</i> Coriolis Flow Meter (Mass Flowmeter) Ultrasonic Flow Meter Magnetic Flow Meter Vortex Flow Meter Positive Displacement Flow Meter Turbine Flow Meter Water Meter Variable Area Flow Meter Rota Flow Meter Paddle Wheel Flow Meter <i>Onsite - Wet Method</i> <i>Clam on by Ultrasonic Flow Meter</i> Series Master Meter Open Channel Flow Meter Measuring Holding Time <i>Onsite - Dry Method</i> <i>Simulate: Electronic Function</i>	Pipe Size \leq 6 inch, DN150 Flow rate up to 140 t/h Flow rate up to 140 m ³ /h Mass up to 2500 kg Volume up to 4500 L
		Pipe Size 0.5 to 200 inch
	Air / Gas Flow Meter Flow Calibrator Mass Flow Meter Turbine Flow Meter Variable Area Flow Meter Rota Flow Meter Wet Gas Meter Dry Gas Meter Air Leak Tester	0 to 280 SLM
	Air Velocity Wind Vane Anemometer Hot Wire Anemometer Pitot Static Tube Anemometer Sonic Probe Anemometer (Ultrasonic) Cup Anemometer Thermal Mass Flow Meter Air Flow Hood	0 to 50 m/s 0 to 1500 Nm ³ /h

	Barometer Digital Barometer Analog Barometer Barograph	745 mbar to 1150 mbar
	Pressure / Vacuum Differential Pressure Transmitter Level Transmitter Pressure Transmitter Flow Transmitter Differential Pressure Indicator Pressure Indicator Pressure Gauge Pressure Switch Safety Valve	- 0.95 bar to 70 bar Medium : Air, N ₂ >70 bar to 700 bar Medium : Oil, Water
	Balance Electronic Balance Mechanic Balance Spring Balance Plate Form Scale	1 mg to 2 ton
	Mass CLASS M1	5 kg , 10 kg , 20 kg
	Volumetric Beaker / Cylinder Volumetric Flask Volumetric Pipet / Measuring Pipet Buret / Digital Buret / Dispenser Pycnometer Micro Syring	1 ml to 20 l
	Dimension Vernier Caliper Micrometer Thickness Gauge	up to 300 mm